

# ASTA

## CERTIFICATE OF TYPE TESTS

Laboratory Ref. No: S2080676

Certificate No. **17032**.....

**APPARATUS:** 0.72/4kV, 50Hz, Window type LT Current Transformer 100/5A,  
Class 1.0, 5VA

**DESIGNATION :** Window type

**MANUFACTURER:** Rishabh Instruments Pvt. Ltd,  
F-31, Satpur, Nasik, Maharashtra, India.

**TESTED BY:** Central Power Research Institute, Switchgear Testing & Development  
Station, Govindpura, Bhopal- 462 023, Madhya Pradesh, India.

**DATE OF TESTS:** 8<sup>th</sup>, 10<sup>th</sup> & 11<sup>th</sup> July 2008

The apparatus, constructed in accordance with the description, drawings and photographs incorporated in this certificate has been subjected to the series of proving tests in accordance with

IEC 60044-1: Edition 1.2, 2003-02 Clause 7.1, 7.2, 11.4 and 11.6

The results are shown in the record of Proving Tests and the oscillograms attached hereto. The values obtained and the general performance are considered to comply with the above standard(s) and to justify the ratings assigned by the manufacturer as stated below.

For ratings assigned by the manufacturer and proved by the tests see page 1

The record of Proving Tests applies only to the apparatus tested. The responsibility for conformity of any apparatus having the same designations with that tested rests with the Manufacturer.

This Certificate comprises 10 pages, 1 diagram, 1 oscillogram, 4 photographs, 1 drawing and no other sheets as detailed on page 2

Only integral reproduction of this Certificate, or reproductions of this page accompanied by any page(s) on which are stated the assigned rated characteristics of the apparatus tested, are permitted without written permission from ASTA BEAB Certification Services, Hilton House, Corporation Street, Rugby. CV21 2DN, England.



010

*A. Awasthi*

A. Awasthi  
ASTA Observer

*P. J. G. Jones*

P. J. G. Jones  
Certification  
Manager

25<sup>TH</sup> SEPTEMBER 2008 Date