P. B. 760, ERDA Road, Makarpura Industrial Estate, Vadodara-390 010, India. Gram: ELECSEARCH EPABX: +91 (0265) 2642942, 2642964, 2642377, 2642557, 2635300, 2635253, 2657784, 2657785.

: +91 (0265) 2638382. E-mail: erda@wilnetonline.net

TEST REPORT



Sheet 1 of 5

NAME & ADDRESS OF CUSTOMER	REPORT NO. T.03/11/020-1		
	DATE : 18.05.2006		
Rishabh Instruments Pvt. Ltd.	CUSTOMER REF. NO.: Email		
F - 31, MIDC,	dtd.06.03.2006		
Satpur,			
Nashik – 422 004.	DATE OF SAMPLE	DATE OF	
	RECEIPT	TESTING	
	04.05.2006	04.05.2006 to	
		18.05.2006	
SAMPLE DESCRIPTION	SAMPLE IDENTIFICATION		
High Voltage Insulation Tester.	ERDA Id. No: TDCCALWO 004762-1		
Make:RISHABH	ERDA Id. No. TBeerin we out 702 1		
Model: Rish Insu 5000 A/AK			
Range: 100 k – 100 M ohm, 100 V,250 V,	}		
500 V,1000 V,1500 V , 2000 V , 2500 V ,			
5000 V.			
10 k-1 Tohm, 100 V,250 V, 500 V,1000 V,1500 V			
2000 V , 2500 V , 5000 V.			
0- 2500 V AC/DC (Measure)			
Accuracy:			
\pm 2.5 % of Scale Length 100 k-100 M ohm,			
100 V, 250 V, 500V,1000 V , 1500 V , 2000 V			
2500 V , 5000 V.			
\pm 5 % of Scale Length 10 k-1 T ohm,			
100 V, 250 V, 500V,1000 V,1500 V,2000 V,			
2500 V, 5000 V.			
Sr No :050194			
Scale length: 111.5 mm			
Meter Size:24 X 24 X 16			
Qty: 1 no			

TEST DETAILS

TEST SPECIFICATION

As per sheet no. 2 of 5

APPROVED BY

Note: 1. This report relates only to the particular sample received in good condition for testing at ERDA.

2. This report cannot be reproduced in part under any circumstances.

3. Publication of this report requires prior permission in writing from Director

4. Only the tests asked for by the customer have been carried.



P. B. 760, ERDA Road, Makarpura Industrial Estate, Vadodara-390 010, India. Gram : ELECSEARCH EPABX : +91 (0265) 2642942, 2642964, 2642377, 2642557, 2635300, 2635253, 2657784, 2657785.

: +91 (0265) 2638382. E-mail: erda@wilnetonline.net



Report No.T.03/11/020-1	Date:18.05.2006	Sheet: 2 of 5
TEST DETAILS	TEST SPECIFICATION	
	Test procedure as per IS 2 per customer requirement	
1. Dry Heat Test.	Clause no.11.11	
2. Dry Cold Test.	Clause no.11.12	
3. Damp Heat Cycling Test.	Clause no.11.13	
4. Error due to variation of level.	Clause no.11.6.1	
5. Error due to stray field.	Clause no. 11.6.4	
O.K. Kapse		*
PREPARED BY	CHECKED BY	



P. B. 760, ERDA Road, Makarpura Industrial Estate, Vadodara-390 010, India. Gram: ELECSEARCH EPABX: +91 (0265) 2642942, 2642964, 2642377, 2642557, 2635300, 2635253, 2657784, 2657785.

: +91 (0265) 2638382 E-mail: erda@wilnetonline.net



Report No.T.03/11/020-1

Date: 18.05.2006

Sheet 3 of 5

Particulars of test and clause no.

No.

Requirement as per specification.

Obtained value

Remarks

Conforms

Dry Heat Test. 1.

> [Test procedure as per clause no 11.11 of IS 2992: 1987 and as per customer requirement.

The test shall be carried out in accordance with IS:9000 (Part 3/ Sec 1 to 4) -1977, the meter shall be subjected to a temperature 55±3°C for a period of 24 hours.

After recovery period of 24 hours, the error shall be within the limits specified as per clause no. 9.

The deviation of the pointer from the true value marked shall be within ± 5 range and % in the first effective \pm 10 % in the second effective range

The deviation of the pointer at the infinity and zero or minimum value marked shall not exceed ± 0.7 % of the scale length.

The deviation of the pointer observed was within \pm 5 % of first effective range and within ± 10 % of effective second

deviation The pointer observed was less than $\pm 0.7 \%$ of the scale length.

range.

O.K.Karse PREPARED BY

CHECKED BY



P. B. 760, ERDA Road, Makarpura Industrial Estate, Vadodara-390 010, India. Gram : ELECSEARCH EPABX : +91 (0265) 2642942, 2642964, 2642377, 2642557, 2635300, 2635253, 2657784, 2657785.

Date: 18.05.2006

: +91 (0265) 2638382. E-mail: erda@wilnetonline.net

Report No.T.03/11/020-1



Sheet 4 of 5

Sr.	Particulars of test R	equirement as per	Obtained value	Remarks
No.	and clause no.	specification.		
2.	Dry Cold Test. [Test procedure as per clause no 11.12 of IS 2992: 1987 and as per customer requirement.]	This test shall be carried out in accordance with IS:9000 (Part 2 /Sec 1 to 3)- 1977. The meter shall be subjected to a temperature of -10°± 3° C for a period of 24 hours. After a recovery period of 24 hours the limits of error shall not exceed the values specified in clause no. 9.		Conforms
		The deviation of the pointer from the true value marked shall be within \pm 5 % in the first effective range and \pm 10 % in the second effective range	The deviation of the pointer observed was within \pm 5 % of first effective range and within \pm 10 % of second effective range.	
		The deviation of the pointer at the infinity and zero or minimum value marked shall not exceed \pm 0.7 % of the scale length.	The deviation of pointer observed was less than \pm 0.7 % of the scale length.	
3.	Damp Heat Cycling Test. [Test procedure as per clause no 11.13 IS 2992 : 1987 and as per customer requirement.]	This test shall be carried out in accordance with IS:9000 (Part 5 /Sec 1)- 1981. The number of cycles shall be 2 and after a recovery period of 24 hours the test shall be carried out for a period of 16 + 8 h cycles, and the error shall not exceed the limits specified in clause no. 9.		Conforms
ā				
00	OK Karse		//	ation Labora
362870	PREPARED BY	CHECKED BY		

P. B. 760, ERDA Road, Makarpura Industrial Estate, Vadodara-390 010, India. Gram: ELECSEARCH EPABX : +91 (0265) 2642942, 2642964, 2642377, 2642557, 2635300, 2635253, 2657784, 2657785. Fax : +91 (0265) 2638382.

Date: 18.05.2006

E-mail : erda@wilnetonline.net

Report No.T.03/11/020-1



Sheet 5 of 5

Sr.		equirement as per	Obtained value	Remarks
No.	and clause no.	specification.		
		The deviation of the pointer from the true value marked shall be within ±5 % in the first effective range and ±10 % in the second effective range.	The deviation of the pointer observed was within ± 5 % of first effective range and within ± 10 % of second effective range.	
		The deviation of the pointer at the infinity and zero or minimum value marked shall not exceed \pm 0.7 % of the scale length.	The deviation of pointer observed was less than \pm 0.7 % of the scale length.	
4.	Error due to variation of level. [Test procedure as per clause no 11.6.1 IS 2992: 1987 and as per customer requirement.]	A change of 5 degrees in the level of the tester, in any direction, shall not results in the deviation of the pointer from its initial position exceeding 0.5 mm.	The deviation of the pointer from its initial position was found less than 0.5 mm.	Conforms
5.	Error Due Stray Field. [Test procedure as per clause no 11.6.4 of IS 2992 : 1987 and as per customer requirement.]	The error of the tester at the central mark shall not exceed \pm 5 percent of the indicated value when the tester is exposed to a magnetic field produced by 400 ampere- turns (dc)in a coil of one meter diameter The tester shall be so placed as to make the influence of the field maximum.	The error of the tester observed was less than ± 5 percent of the indicated value at the central mark.	Conforms

6 K Karse PREPARED BY

CHECKED BY

